

PRODUCT CERTIFICATE OF REGISTRATION



Global Certification Pty Ltd

Number 564

Product Performance Testing

AS 1546.3:2017

Advanced Secondary 10EP Level

Issued to

Rivatec Environmental Pty Ltd

6 Marklea Close, Tuggerah, NSW 2259

Certification Date: - 6/05/2020

Expiry Date: - 5/05/2025

Product Certified:

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
Rivatec RWT10-2	Yes	TSS 7.18 mg/l BOD ₅ <2 mg/l Total Nitrogen 31.62 mg/l Phosphorus 11.61 mg/l Turbidity 10.22 NTU E coli <1CFU/100ml	3 Monthly Service 3.2 yearly sedimentation pump out or as required	Pumped via disinfection/pump chamber with chlorine dispenser	Manufactured at 5 Marklea Close Tuggerah, NSW 2258 Assembled: at 6 Marklea Close, Tuggerah, NSW 2259

The system took 4 weeks to meet the advanced secondary standard.

NACE CODES: 3700

This Certificate of Conformance to the Product Certificate Scheme remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 6th May 2020


Bruce Smith Director



www.jas-anz.com.au/register

Signed for and on behalf of Global Certification Pty Ltd
PO Box 195, Morayfield QLD 4506