

JOINT RECORD DATABASE



Joint Number 93	Utility Gas	Depth Of Main 1.1m
Purchase Order Number 1234567890	RO / NRO Number UKD/000000/ROU	☐ Current Profile Graph Checked?
Invoice Number 00000	Parent Main Diameter 30"	☐ Fusion Box Printout Checked?
Customer Contact Name & Number Joe Bloggs - Tel : 01234 567 890	Parent Main Material Type Cast Iron	Pressure Test Checked By Gavin Alberry
Company Joe Bloggs Ltd	Parent Main SDR N/A	☒ Pressure Test Passed?
Street A Street	Parent Main Batch Number N/A	☒ Pressure Test Cert Left On Site?
Town Burnley	Branch Saddle Size 30" x DN300 Reduced To DN150	☒ Installation Drilled?
City County	Branch Saddle Serial Number N/A	☒ Coupon Recovered?
County Lancashire	Stub Flange Kit Batch Number N/A	Drill Hole Diameter 140mm
Post Code Installation Date 18/01/2013	Valve Type Donkin 555 Gate Valve	☐ Blank Plate Fitted?
Competent Person Gavin Alberry	Valve Serial Number 16 26 93	Site Observations Excavation outside House No. 123. Clip installed at 45° facing upwards with a DN300xDN150 flange adaptor bolted straight onto the flange. Valve installed upright as requested. Gangers to piece straight onto valve.
Assistant Ryan Alberry	☒ Customer Valve Installed?	Record Created by Gavin Alberry
	☒ Pressure Point Installed?	
	Parent Mains Pressure 29 mbar	



Pneumatic Pressure Test Certificate - Metallic Branch Saddles

Installation Number	Jt 93
Location	A Street, Burnley
Date	Friday 18th January 2013
Fitting Details	30" x DN300 c/w DN300 x DN150 Flange Converter
Design Pressure (MOP)	75mbar
Test Specification	IGE/GL2/Issue 4

Initial Pressurisation Time	12:28
Test Commenced Time	12:35
Test Completed Time	12:50
Completed by	G Alberry

Gauge Type	Druck	Calibration / Plant No.	30
Calibration Date	Mar-12	Calibration due	Mar-13

Conditioning Time 7 mins Test Period 15mins
Test Pressure 350mbar Creep Allowance Zero

Pneumatic Report	Test On	Intermediate Reading	Test Off	Total Loss
Pressure	394	394	394	0

Test Result : PASS

Test Accepted by	Sign 	Print G Alberry
Position	Site Technician	
Company	PE WeldRight Ltd	



ELECTROFUSION & BUTT FUSION
TECHNICAL SUPPORT

PE WeldRight Ltd | Unit 6 | Speedwell Industrial Estate
Fan Road | Staveley | Chesterfield | Derbyshire | S43 3PT
T: 01246 472777 | M: 07989 101 179 | F: 01246 472777
E: enquiries@peweldright.co.uk | W: www.peweldright.co.uk
Company Registered No. 6970008 | VAT no. 129813304

