<form><section-header><section-header>

- 1. A significant hazard associated with hot work is accidental fire:
 - a. True

2. ____

b. False

_____ is always required when performing hot work:

- a. Respiratory protection
- b. Eye protection
- 3. A ______ is always required in areas where hot work is performed:
 - a. Drinking fountain
 - b. Fire extinguisher
- 4. Precautions must be taken to protect passers-by from rays and hot objects:
 - a. True
 - b. False
- 5. A ______ area is designed and maintained to be safe for hot work to be done:
 - a. Designated
 - b. Special
- 6. A ______ procedure is used to prepare areas where welding, cutting and brazing are not normally done:
 - a. Training and orientation
 - b. Hot work permit
- 7. Only personnel who are ______ are allowed to perform hot work:
 - a. Very strong and intelligent
 - b. Trained and authorized
- 8. An accidental fire can be caused by heat transmitted through a pipe or duct:
 - a. True
 - b. False

9. Sparks and slag can pass through a wall or floor opening to start a fire:

- a. True
- b. False

10. When performing hot work in confined spaces ______ is required:

- a. New gloves
- b. Mechanical ventilation